



Environmental Health Division
 Water Quality Section
 400 W. Market St.
 Suite 300
 Greensboro, NC 27401
 (336) 641-7613



Improvement Permit

Address: 7904 Backridge DR Permit Number: 22-03-SNHR-01747

This Improvement Permit shall be valid for five years from the date issued upon a satisfactory showing to the health department that the site and soil conditions are unaltered, that the facility, design wastewater flow, and wastewater characteristics are not increased, and that the wastewater system can be installed to meet the following requirements that were in effect on the date the Improvement Permit was issued.

Design Flow 480
 Facility Type Residence
 Number of Bedrooms 4

Conditions Lot # 85

EXISTING GULLY TO BE FILLED IN TO
 REDUCE SETBACKS FROM APPROVED AREA BEFORE CA.


Do not grade or disturb the approved area. Disturbance of this area, change of site plan, or change of intended use could result in the suspension or revocation of this permit. This is not an authorization to construct a wastewater system. The authorization for wastewater system construction with system specifications must be completed before any building permits or system installation can commence.

Permit Issued: Shane B. Row
 Environmental Health Specialist

Date Issued: 7/5/12



Diagram



Address: 7904 Backridge Dr
 Permit #: 22-03-SNHR-01747
 Issuer's Initials: SKB
 Date: 7/5/2022




1 inch = 120 feet

DISCLAIMER:
 The data shown in this map is for public use. Guilford County makes no warranty to its accuracy; all data sets and maps are for geographical representation only.

#	1	2	3	4	5	6	7	8	100
landscp	L	L	L	L	L	T	L	L	L
slope	14	10	14	7	12	3	22	17	22
H1_depth	0 - 11	0 - 6	0 - 11	0 - 6	0 - 11	0 - 6	0 - 10	0 - 19	0 - 8
H1_text	SCL	CL	SCL	SCL	SCL	Fill	SCL	Clay	SCL
H1_consist	Fr	Fr	Fr	Fr	Fr	Fr	Fr	Fi	Fr
H1_struct	WBK	WBK	WBK	WBK	WBK	M	WBK	BK	WBK
H1_minrl	SEXP	SEXP	SEXP	SEXP	SEXP	SEXP	SEXP	SEXP	SEXP
H2_depth	11 - 25	6 - 22	11 - 22	6 - 17	11 - 27	6 - 20	10 - 25	19 - 48	8 - 29
H2_text	Clay	Clay	Clay	Clay	Clay	Clay	Clay	CR	Clay
H2_consist	Fi	Fi	Fi	Fi	Fi	Fi	Fi		Fi
H2_struct	SBK	BK	SBK	BK	SBK	SBK	SBK		SBK
H2_minrl	SEXP	SEXP	SEXP	SEXP	SEXP	SEXP	SEXP		SEXP
H3_depth	25 - 52	22 - 41	22 - 40	17 - 25	27 - 38	20 - 34	25 - 54		29 - 48
H3_text	CL (BC)	CL (BC)	CL (BC)	CL (BC)	CL (BC)	CL (BC)	CL (BC)		CL (BC)
H3_consist	Fr	Fr	Fr	Fr	Fr	Fr	Fr		Fr
H3_struct	WBK	WBK	WBK	WBK	WBK	WBK	WBK		wSBK
H3_minrl	SEXP	SEXP	SEXP	SEXP	SEXP	SEXP	SEXP		SEXP
H4_depth			40 - 40	25 - 48	38 - 38	34 - 34			
H4_text			CR	Rock	CR	Rock			
H4_consist									
H4_struct									
H4_minrl									
soil_wet									
saprolite									
class	PS	ps	PS	ps	PS	PS	PS	ps	PS
ltar	0.25	0.225	0.225	0.225	0.25	0.225	0.25	0.1	0.25
notes			CR	rock	CR	Gravel		drip	
eval_by	SKB	JBS	SKB	JBS	SKB	SKB	SKB	JBS	JPS
eval_date	04/05/22	04/05/22	04/05/22	04/05/22	04/05/22	04/05/22	04/05/22	04/05/22	04/05/22
Initial/Repair LTAR	.25/.1					.25/.1			
Initial/Repair System Type	ppbps/drip					ppbps/drip			

#	101	300
landscp	L	L
slope	21	20
H1_depth	0 - 24	0 - 9
H1_text	Clay	SCL
H1_consist	Fi	Fr
H1_struct	BK	WBK
H1_minrl	SEXP	SEXP
H2_depth	24 - 40	9 - 28
H2_text	CR	Clay
H2_consist		Fi
H2_struct		BK
H2_minrl		SEXP
H3_depth		28 - 38
H3_text		CL (BC)
H3_consist		Fr
H3_struct		WBK
H3_minrl		SEXP
H4_depth		38 - 38
H4_text		Rock
H4_consist		
H4_struct		
H4_minrl		
soil_wet		
saprolite		
class	ps	PS
ltar	0.25	0.275
notes	cr	Rock
eval_by	JBS	SKB
eval_date	04/05/22	01/01/00
Initial/Repair LTAR		
Initial/Repair System Type		



110' STREAM & DRAINAGE ESMT (55' ON EACH SIDE OF TOP OF BANK)

Gully

Top of Cut

FILL
IN GULLY
TO REDUCE
SETBACK
TO S'
CUTS TO
STIFFEN
ON PERMIT



**GUILFORD COUNTY
PLANNING AND DEVELOPMENT**

**Improvement Permit
Application**

22.03.SNHR.01747

Building Permit # 1904 Septic # _____ Well # _____

Property Information

Address Backridge Drive City Stokesdale State NC Zip 27357

Tax Parcel # _____ Township: _____

Development Name: Northridge Phase 6 .98 ac

Section/Phase: 6 Lot #: 85 Deed Book: 8562 Page: 007 Plat Book: _____ Page: _____

Lot of Record First Lot Out Plat Required > 5 Acres (5-17-65 to 2-1-74) > 10Acres (2-1-74 to Present)

Located in recorded roadway corridor, do not permit. Contact NCDOT

Zoning Information

Zoning: RS-40 Conditional Zoning (Describe): _____

Overlay (Check): MH SR HD AR FH

Watershed: N/A Watershed Critical Area: _____

Building Setbacks (Zoning): Front Street: 45 Side Street: 40 Side Yard: 15 Rear: 30

Comments: _____

PLANNING DEPARTMENT OFFICIAL: _____

Applicant Information

Brent Sievers 8518 Triad Drive Colfax, NC 27235 336-544-6432 bsievers@flemingengineering.com

Applicant Name Address Phone Email

Northridge, LLC 8518 Traid Drive Colfax, NC 27235 336-852-9797

Owner Name Address Phone Email

Development Information

NEW ACCESSORY SWMH MULTIFAMILY/DUPLEX ADDITION (TYPE) _____
 HOUSE MODULAR DBMH RENOVATION OTHER TYPE: _____

Residential Specifications: 4 # of Bedrooms _____ Total # of Rooms _____ # of Occupants _____
_____ Basement (Y or N) No Basement Fixtures _____ # of Stories _____ Size of Structure (sq ft) _____

Non Residential Type: Commercial Industrial Other _____
_____ # of Employees _____ # of Fixtures _____ Plumbing _____ # of Stories _____
_____ Size of Structure (sq ft) Restaurant # of seats: _____ Church w/kitchen _____

Water Information: New Well Existing Well Public Community Well _____

Sewage Disposal: Conventional Chamber Trench Polystyrene Aggregate Low Pressure Pipe
 Lg. Diameter Pipe PTI Multi-pipe Drip Irrigation PPBPS Pre-Treatment

Other (specify) _____

Directions: _____

A Plat or Plot Plan must accompany this application. Clearly stake and flag all property lines, corners and the corners of all structures.

I have read this application and certify that the information provided herein is true, complete and correct to the best of my knowledge, and is given in good faith. Authorized County and State Officials are granted right of entry to conduct necessary inspections to determine compliance with applicable rules. The owner/applicant is solely responsible for compliance with the applicable governing regulations.

B. J. C. Smith
Owner/Applicant Signature

03/07/22
Date